

Phone : (0522)-2452501
Telephone: (0522)-2465715
Telegram : RAILMANAK, LKO
Email: dell7@vsnl.net.gov.in



भारत सरकार - रेल मंत्रालय
अनुसंधान और मानक संगठन
लखनऊ - 226011
Government of India - Ministry of Railways
Research, Designs & Standards
Organization, LUCKNOW - 226011

से. ई. एन./२२.२९

दिनांक 25.06.2009

मुख्य विद्युत अभियंता,

1. मध्य रेलवे, मुम्बई सीएसटी - 400 001
2. पूर्व रेलवे, कोयला प्लेस, कोयंबटूर - 700 001
3. पूर्व रेलवे, बन्दरगाह, मुंबई - 751 015
4. उत्तर रेलवे, बल्लोदा हाऊस, गई दिल्ली - 110 001
5. उत्तर मध्य रेलवे, मुख्यालय, बल्लोदा ए. जूनेनामगांव, इलाहाबाद - 211 003
6. दक्षिण रेलवे, गार्डन टाउन, चेन्नई - 000 003
7. दक्षिण मध्य रेलवे, रेल निहायम, शिकंदराबाद - 500 071
8. दक्षिण पूर्व रेलवे, गार्डन टी. कोलकाता - 700 003
9. दक्षिण पश्चिम रेलवे, मुम्बई
10. पश्चिम रेलवे, बल्लोदा, मुम्बई - 400 020
11. पश्चिम मध्य रेलवे, बल्लोदा - 400 001
12. दक्षिण पूर्व मध्य रेलवे, बल्लोदा - 400 004
13. पूर्व-मध्य रेलवे, बल्लोदा - 400 101
14. उत्तर-मध्य रेलवे, बल्लोदा, बल्लोदा - 710 003

विषय : एसी एमटीआरएफ सिस्टम वॉल्यूम १ सी.टी.आर.एफ. रिले के पोर्ट कनेक्शन के
रीलीफेड करने - माडिफिकेशन शीट नं० आरडीएसओ/२००९/ईएल/एनएन/०३२०,
विशेषज्ञता जा जारी होगा।

उपरोक्त विषय में इस कार्यालय का दिनांक 23.06.2009 का समसंलग्न पत्र आपकी सूचना एवं
आवश्यक कार्यवाही हेतु इस पत्र के साथ संलग्न है।

संलग्नक संशोधन।

(एम. सी. महन्त)
मुख्य महानिदेशक/विद्युत

प्रतिलिपि:-

मानक मंत्रालय लिस्ट नं० ईएल/एन/०३२०, परचम २ के अनुसार।

संलग्नक संशोधन।

(एम. सी. महन्त)
मुख्य महानिदेशक/विद्युत

Telephone : 2489 XXX
2480 XXX
Fax : 81-0522-2458500



भारत सरकार - रेल मंत्रालय
संशोधन और मानक संगठन
लुधियाना - 226 011
Government of India-Ministry of Railways
Research Designs & Standards Organisation
Lucknow - 226 011

AN ISO 9001
CERTIFIED
ORGANISATION

No. EL/3.2.29

Dated 23.06.2009

Chief Electrical Engineer,

- Central Railway, Mumbai CST- 400 001.
- Eastern Railway, Fairlie Place, Kolkata- 700 001
- East Coast Railway, Chandrasekharpur, Bhubaneswar- 751 016.
- Northern Railway, Baroda House, New Delhi-110 001
- North Central Railway, Hasting Road, Allahabad-211 001.
- Southern Railway, Park Town, Chennai-600 003
- South Central Railway, Rail Nilayam, Secunderabad -500 071
- South Eastern Railway, Garden Reach, Kolkata 700 043
- South Western Railway, Hubli.
- Western Railway, Churchgate, Mumbai-100 020
- West Central Railway, Jabalpur 482001
- South East Central Railway, Bilaspur-495004
- East Central Railway, Hazipur-844101 (Bihar)
- Chittaranjan Locomotive Works, Chittaranjan- 713 331

MODIFICATION SHEET No. RDSO/2009/EL/MS/0379, Rev.'O'

Dated 15.06.2009

1. TITLE :

Relocation of port connection of QVRF relay provided on AC MVRF fitted vertical DBR.

2. OBJECT :

RDSO vide Modification sheet no. RDSO/2006/EL/MS/0348, REV. 'O' dated 22.09.2006 have advised Railways for retro fitment of AC MVRF in place of existing DC MVRF provided in vertical DBR. Railways have reported burning of cable conduit of AC MVRF. Investigation reveals in some cases, due to reverse direction of rotation of MVRF hot air throws over the motor body causing burning of MVRF cable lead and damage to paint surface of MVRF. In normal working of MVRF the air is supposed to flow from bottom of DBR to top after cooling the motor and exchanging the heat from the resistor element.

However to ensure the normal functioning of MVRF, QVRF relay has been provided. The low pressure port of the QVRF relay is fitted at the location below the blower fan and due to negative pressure, the QVRF relay picks up.

During investigation it is observed that in reverse direction of rotation of MVRF also QVRF relay picks up. The pressure at the existing location during reverse direction of MVRF has been measured and found that a negative pressure of about 52 mm WC is developed, due to projection of nozzle of about 7.5 mm causing picking of QVRF relay. The present setting of QVRF relay as per RDSO's Technical Circular no.ELRS/TC/0072-2001 (Rev. '0') dated 28.09.2001 is to pick- up between 12 (+0, -2) mm WC.

To eliminate the above problem the following modification is to be carried out.

3. EXISTING ARRANGEMENT :

In the existing arrangement the negative air flow is sensed by QVRF relay through low pressure port of the QVRF relay connected to $\frac{1}{8}$ " nozzle through steel braided rubber tube, mounted 25 $\pm$ 5mm below the blower fan. Pressure setting of the QVRF relay is -12(+0,-2) mm WC.

4. MODIFIED ARRANGEMENT :

To eliminate the sensing of the QVRF relay during reverse direction of MVRF, the sensing location of the air flow has been shifted from bottom of the fan blade to top side of the fan on inspection cover of MVRF provided on blower surface.

For mounting of the nozzle following works are to be done:-

- i) Drill 1.3mm $\varnothing$ hole on the inspection cover for MVRF bolted on the casing of the blower as shown in the RDSO' Drawing no. SKEL - 4762 (Rev. '0').
- ii) $\frac{1}{8}$ " elbow to be fixed up and ensure that 'L' portion should be vertically down ward position.
- iii) Apply araldite on the fixing location to ensure that the elbow nipple should not rotate.
- iv) Remove the flexible connection from the existing nipple and connect it to elbow nipple mounted on MVRF inspection cover.
- v) Change the connection on QVRF from low pressure port to high pressure port.
- vi) Ensure the QVRF relay connection.
- vii) Check the direction of rotation of Blower, the air flows from bottom side of DBR to top of the DBR.

- viii) Check the operation of QVRF relay it should pickup only in the direction of air flow from bottom to top side of the DBR. In case of reverse direction of rotation of MVRF, QVRF relay should not pick up.

5. APPLICATION TO CLASS OF LOCOMOTIVE:

All conventional Electric Locomotives having vertical DBR's with AC MVRF

6. MATERIAL REQUIRED :

1/2" brass elbow.

7. MATERIAL RENDERED SURPLUS :

1/2" brass nipple.

8. REFERENCE:

9. MODIFICATION DRAWING:

As per RDSO Drawing no. SKEL - 4762 (Rev. '0').

10. AGENCY FOR IMPLEMENTATION :

All Electric Loco Sheds, POH Shops & CLW/Chittaranjan.


Encl: As above

Copy to: As per Standard Mailing List No. EL/M/0019, Ver. '2'

(Sandeep Srivastava)
for Director General/Elect.

Encl: As above

4/23/06
(Sandeep Srivastava)
for Director General/Elect.



ELBOW

PAP' NO	DESCRIPTION	QUANTITY
7068	RELOCATION OF AIR SENSING NOZEL OF QVRF	FIRST ISSUED 1009 SUPERSEDED
7069	RELIEF VALVE SUPPLEMENTED BY AIR OIL	

[illegible]