

Research Designs and Standards Organisation
(Traction Installation Directorate)

Reasoned document of TI/STR/040 for SILVER BEARING GROOVED COPPER CONTACT WIRE FOR 25kV, 50 Hz ELECTRIC TRACTION

1. STR no. TI/STR/040 for SILVER BEARING GROOVED COPPER CONTACT WIRE FOR 25kV, 50 Hz ELECTRIC TRACTION was uploaded on RDSO website for 15 days for seeking comments,
2. Comments/Suggestion received from viewers are as below.

Clause No.	Particular in Draft STR	Comments Received	RDSO Remarks
2.1.1(i)	---	<u>CORE Allahabad</u> Specification may be reviewed to include the checks required to ensure correctness of counter, to avoid cases of supply of short drum lengths of Contact wire on account of faulty counter meter.	May be accepted.
3.11	It should be ensured that identification details like maker's name, year and month of manufacture are embossed on the finished product.	<u>M/s KEC, M/s Chandra Metals</u> <u>M/s JK Cables</u> As per clause 3.12, embossing patterns are defined as CCC/MMM/YY where month is not defined on finished product.	May be accepted.