

Research Designs and Standards Organisation  
(Traction Installation Directorate)

Reasoned document of RDSO's Specification No. TI/SPC/OHE/HDCSCF/0031 for Hard Drawn Stranded Copper Conductor.

RDSO's Specification No. TI/SPC/OHE/HDCSCF/0031 for Hard Drawn Stranded Copper Conductor was uploaded on RDSO website for 15 days dated 15.09.2020 for seeking comments,

1. Comments/Suggestion received from viewers are as below.

Clause No.	Particular	Comments Recieved	RDSO's Remark
14.1	The oxygen content shall be verified from the supplier's certificate	---	Determination of oxygen content by Spectrometer or oxygen analyser included
15.1 & 15.2	----	<b><u>CORE/Allahabad</u></b> Specification may be reviewed to include the checks required to ensure correctness of counter, to avoid cases of supply of short drum lengths of Contact wire on account of faulty counter meter. Specification may be reviewed to include the aspect of actual weighment of Tare weight of drum during RITES inspection.	May be accepted.
15.4	Weightment of three or one fifth of offered drums whichever is higher shall be made for tare weight and gross weight .	<b><u>CORE/Allahabad</u></b> Specification may be reviewed to include the aspect of actual weighment of Tare weight of drum during RITES inspection.	May be accepted.
18.9.1	Weightment of three or one fifth of offered drums whichever is higher shall be made for gross weight and recorded.	<b><u>CORE/Allahabad</u></b> Specification may be reviewed to include the aspect of actual weighment of Tare weight of drum during RITES inspection	May be accepted.