

Research Designs and Standards Organisation  
(Traction Installation Directorate)

Reasoned document of TI/STR/020(Rev 2) for Stranded Cadmium Copper Conductors.

1. STR no. TI/STR/020(Rev 2) for Stranded Cadmium Copper Conductors was uploaded on RDSO website for 15 days dated 28.08.2020 for seeking comments,
2. Comments/Suggestion received from viewers are as below.

Clause No.	Particular in Draft STR	Comments Received	RDSO Remarks
2.2.1(l)	-----	<p><b><u>CORE Allahabad</u></b></p> <p>Specification may be reviewed to include the checks required to ensure correctness of counter, to avoid cases of supply of short drum lengths of Contact wire on account of faulty counter meter.</p>	May be accepted