


Telegram  
टेलीग्राम/Tele

पता/Address :  
'RAILMANAK', Lucknow  
451200 (PBX)  
450567 (DID)



सत्यमेव जयते

गाम्भिर्यम्  
अनुसंधान अभिकल्प और मानक संगठन  
लखनऊ - 226011  
Government of India-Ministry of Railways  
Research Design & Standards Organisation  
Lucknow - 226011



No. SII/RL/WS/PSE/378

Dated 30.4.2001

To : As per list overleaf.

Amendment No. 1

Sub:- Power Supply Unit ( PSU ) for  
Telecom Installations at Way Side  
Station in 25KV Electrified Areas to  
Specification No. IRS: TC 72-97.

A new clause has been included as under in the  
specification No. IRS:TC 72-97 for Power Supply Unit (PSU)  
for Telecom Installation at Way Side Station in 25KV  
Electrified Areas.

New Clause

Cl. 4.7.3 - " Battery shall get disconnected from the  
load in absence of mains ( 230V AC ) whenever  
Battery Voltage falls to 10.8V. When 230V  
mains resume, the battery shall automatically  
get connected in float charge mode."

This is for your information and reference.

*Nareh*  
( Nareh Saini )  
for Director General/Telecom.

o/c

The GM (S&T)

- \* Central Railway, Mumbai C.S.T.
- \* Eastern Railway, Fairlie Place, Calcutta.
- \* Northern Railway, Baroda House, New Delhi.
- \* North Eastern Railway, Gorakhpur.
- \* N.E. Railway, Maligaon, Guwahati.
- \* Southern Railway, Park Town, Chennai.
- \* South Central Railway, Rail Nilayam, Secunderabad.
- \* South Eastern Railway, Garden Reach, Calcutta.
- \* Western Railway, Churchgate, Mumbai.
  
- \* The Director/IRISET/Secunderabad.
- \* GM(S&T)/CORE, Allahabad.
- \* CPA/IRCOT, IRCOT Complex, 1st Floor, Shivaji Bridge Behind Shanker Market, New Delhi.
- \* Director/Jt. Director Inspection(S&T)/RDSO,
  - i) 4th Floor, West Wing, 17, N.S. Road, Calcutta.
  - ii) 1st Floor, RDSO Inspection Office, Behind Shanker Market, Shivaji Bridge, New Delhi.
  - iii) 3rd Floor, Rly. Divl. Office Building, Bangalore.
  - iv) 1st Floor, New Annexe Building, Western Railway, MUMBAI

Naresh  
( NARESH SAINI )  
for Director General/Telecom.

Copy to :

1. M/s. Bentron Power Systems, 21/1, Kedarnath Chatterji Road, Behala, Calcutta- 700 034.
2. M/s. Indisco, 8, Uptron Estate, Panki, Kanpur.
3. M/s. Epsilon Elec. Equipments & Components Ltd., B-2, Electronic Industrial Estate, Kushaiguda, Hyderabad-62
4. M/s. Spark Enterprises, B-23/A. Electronic Complex, Kushaiguda, Hyderabad- 62.
5. M/s. Ex-Servicemen Electrical Industries, B-16, SIDCO Industrial Estate, Villivakkam, CHENNAI P.W.-600 049