



SIDE VIEW

NOTE:

1. All dimension are in mm.
2. Thickness shall be minimum 3 mm & maximum 4 mm.
3. Tolerance ± 3 mm for length, width, height & ± 0.5 mm for hole dia. and radius.
4. Size of Cable Gland Inner Hole Dia. should be $(24 \pm 0.5 \text{mm})$
5. Space between CT box body and insulating plate should be $7 \pm 1 \text{mm}$
6. Size of Insulating Plate should be $(346 \text{mm} \times 212 \text{mm} \times 4 \text{mm}) \pm 1 \text{mm}$.
7. Depth of Insert should be 20.0 mm (Minimum)

TOP VIEW

MATL & SPEC	ABS TC/97
-------------	--------------

SCALE	Do Not Scale	ALT 1	Description	Date
Done By	Checked By	Approved By		

TC 4340	BASE	1
PART NO.	DESCRIPTION	NO. REQD.
R. D. S. O.		
TELECOM CABLE TERMINATION BOX FOR TELECOM CABLES, POWER CABLES SPD's AND FUSE ETC.		
-BASE-		
TC 4340 (ADV) WITH ALT-1		