

**Reasoned Document for final draft of the STR**

On the draft of the STR no. TI/STR/013 Revision-III, comment of only one firm i.e. M/s Bharat petroleum Corporation Limited has been received. The received comments are as below:

<b>SN</b>	<b>Para of STR</b>	<b>Draft description</b>	<b>STR</b>	<b>Comment of the firm</b>	<b>RDSO's Comments</b>
1.	2.6 (A)	Oil as per IS: 12463 and IEC: 60296 both		Please replace IS:12463 with IS:335	Accepted as now oil as per IS 335 is used
2.	2.6 (A-ii)	Hydrometers		Along with hydrometers please allow Auto Densitometers also as these are commonly used in plants and follows ASTM D 4052	Accepted for both options
3.	2.6 (A -xi)	Apparatus for Specific Resistance		Please remove as the test is not the part of the new IS:335:2018	Accepted as now oil as per IS 335 is used
4.	2.6(A- xiii)	Apparatus for ageing characteristics		Please remove as the test is not the part of the new IS:335:2018	Accepted as now oil as per IS 335 is used